

FILE

Frank L. O'Bannon
Governor

Gregory A. Wilson, M.D.
State Health Commissioner



Indiana State Department of Health

An Equal Opportunity Employer

January 28, 2002

Mr. John C. McGrath
Quality Manager
Baughman Tile Company
8516 Twp. Rd. 137
Paulding, Ohio 45879

Dear Mr. McGrath:

Re: 3-wall pipe approval
Baughman Tile Company

This is in response to your letter requesting approval of your company's 3-wall pipe for use in absorption fields in Indiana. Your letter states that the pipe is produced to ASTM F-810 and ASTM F-405. You stated in a recent telephone conversation that those ASTM numbers are stamped on the pipe. Your letter also states that the perforations in the 4 inch pipe are in rows separated by 120 degrees and are 5/8 or 3/4 in diameter and spaced on 4 inch centers.

Your company's perforated pipe, as described in your letter, meets our minimum requirements for use in absorption fields in Indiana.

A copy of our List of Acceptable Pipe is enclosed for your reference. If you have any questions, please do not hesitate to let me know.

Sincerely,

Alan M. Dunn, R.E.H.S., Supervisor
Residential Sewage Disposal
Sanitary Engineering
(AC) 317/233-7177

Enclosure

cc: Local Health Departments
Onsite staff